

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7167-1157:103 Page 1 of 1

**CATEGORY:** Control Unit (Household)

**LISTEE:** Digital Monitoring Products, 2500 N. Partnership Blvd., Springfield MO 65803  
Contact: Terry Shelton (417) 831-9362 FAX (417) 831-1325

**DESIGN:** Models XR6, XRSuper6, XR10, XR20, and XR40 combination household fire and burglary alarm control units. Inherent power limited. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

349, 350A	Enclosure
670, *690, 692, 770, 771, *790, *791, *793	Keypad
714, *714-8, *714-16, 715, *715-8, *715-16	Loop Expander
321, 324	Plug-in Transformer

**RATING:** Primary 120 VAC, Secondary 16.5 VAC, Standby 12 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 5 minutes of alarm as required by code.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as combination household fire and burglary alarm control units for use with separately listed electrically compatible initiating and indicating devices. These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to listee's Installation Instructions Manual for details.

**NOTE:**

1. The **Fire Alarm Verification Feature** (delay of fire alarm signal) is NOT approved for use in California. This feature shall not be programmed into the unit.
2. Burglary and other non-fire functions not examined.

\*Rev. 11-25-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

Listing Expires **June 30, 2005**

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**